

ORDINANCE NO. \_\_

AN ORDINANCE TO AMEND SECTION 5-I-8 B (17) OF THE GILLETTE  
CITY CODE

BE IT ORDAINED BY THE GOVERNING BODY OF THE CITY OF  
GILLETTE, WYOMING:

SECTION ONE. Section 5-I-8 B (17) is amended to read as follows:

(17) Section 506.1 *Where Required* of the International Fire Code is  
amended to read as follows:

**506.1 Where Required.** Key boxes shall be provided for Fire Department entry  
for all commercial occupancies, within the City of Gillette, that have a sprinkler  
system or a fire alarm and are not constantly attended 24 hours per day. The key  
boxes shall be installed on all new businesses before occupancy is granted. Any  
existing businesses that obtained a permit to do any work or change of use or  
occupancy which includes the installation of a sprinkler system or a fire alarm and  
are not constantly attended 24 hours per day, shall be required to install a key box  
before the work can be completed and signed off and occupancy resumed. The key  
box shall be located within 10 feet of the front doors, a minimum of 6 six feet  
above the ground level and not to exceed 7 seven feet in height unless approved in  
writing by the fire code official. The key box shall be of an approved type and shall  
contain keys to gain necessary access as required by the fire code official. (Ord.  
3549, 5-5-08; Ord. 3691, 9-7-2010; Ord. 3771, 8-20-2012; Ord. 3817, 4-15-2014)

PASSED, APPROVED AND ADOPTED this \_\_\_\_ day of \_\_\_\_\_, 2014.

---

John Opseth, Mayor

( S E A L )

ATTEST:

---

Karlene Abelseth, City Clerk

Published: