

**CITY OF GILLETTE  
CERTIFICATE OF FINAL COMPLETION**

Project: Gillette Regional Water Supply Project Force Road Road Joint Powers Board District Connection Project

Project No.: 12UT05

Date of Contract: December 11, 2017

Owner: City of Gillette

Contractor: Hot Iron, Inc

Engineer: DOWL

**This Certificate of Final Completion applies to:**

  X   All Work under the Contract Documents:

       The following specified portions:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

May 30, 2018  
Date of Final Completion

The Work to which this Certificate applies has been inspected by authorized representatives of Owner, Contractor and Engineer, and found to be complete in accordance with the Contract Documents.

The project will be advertised according to W.S. 16-6-166, and the Affidavit on Behalf of the Contractor is attached to and made part of this Certificate

  
\_\_\_\_\_  
Executed by Contractor

6-5-18  
\_\_\_\_\_  
Date

  
\_\_\_\_\_  
Executed by Engineer

6-1-18  
\_\_\_\_\_  
Date

  
\_\_\_\_\_  
Executed by Owner

6/6/18  
\_\_\_\_\_  
Date



## PUNCHLIST

PROJECT: Force Road Joint Powers Board District Connection PROJECT #: 12UT05

LOCATION: Force Road Joint Powers Board District Building

Items noted represent specific deviations and discrepancies, which must be corrected or finished. Any and all such deviations and discrepancies, whether or not specifically noted, are hereby included by reference.

The following items are to be completed or corrected to comply with the Contract Documents. Additional punch list items will be added as identified during project cleanup and closeout.

DESCRIPTION / ITEM	APPROVED BY ENGINEER / DATE COMPLETED
Smooth Out Grading Around District Connection Point & Tank	5-30-18
Complete Seeding & Erosion Control	5-30-18
Install Final Interior Pipe Supports	5-30-18
Finish installation of the Flushing Connection	5-30-18
Complete Additional Barbwire Fence & Gate	5-30-18
Trim spray foam back at the top of the door in the interior and caulk gap	5-30-18
Correct the Caulking at the Northwest Building Joint – Caulk has Separated from the Edges at Some Locations	5-30-18
Final Walk Through	5-30-18
Provide Close Out Documents Including O&M Manuals	6-5-18
Installation of Gate Holders	5-30-18

Completion of Punchlist Items Approved

  
Project Engineer

6-1-18  
Date